

ORDINANCE NO. 3134

TITLE: An Ordinance amending Section 5 of Ordinance No. 2740, establishing the limits of districts in which storage of flammable liquids in bulk plants is allowed and declaring an emergency.

THE PEOPLE OF THE CITY OF ALBANY DO ORDAIN AS FOLLOWS:

Section 1: AMENDMENT

Section 5 of Ordinance No. 2740 is amended to read as follows:

"Section 5: ESTABLISHMENT OF LIMITS AND DISTRICTS IN WHICH STORAGE OF FLAMMABLE LIQUIDS AND OUTSIDE ABOVE GROUND TANKS IS TO BE PROHIBITED.

(a) Storage of flammable liquids in outside above ground tanks is prohibited within the city limits, except as shall be allowed by the Chief of the Bureau of Fire Prevention under Section 8 of this Ordinance.

(b) New bulk plants for flammable liquids may be built only in M-2 medium industrial zones and M-3 heavy industrial zones as defined in Ordinance No. 2916 and no new bulk plant shall be erected within 250 feet of the Calapooya River or the Willamette River."

Section 2: EMERGENCY CLAUSE

Inasmuch as the provisions of this Ordinance is necessary for the immediate preservation of the peace, health and safety of the citizens of the City of Albany, Oregon, an emergency is hereby declared to exist and this Ordinance shall be in full force and effect immediately on its passage by the Council and approval by the Mayor.


Passed by the Council: July 8, 1964

Approved by the Mayor: July 8, 1964


Mayor

Effective Date: July 8, 1964

ATTEST:


City Recorder