

RESOLUTION NO. 595


WHEREAS, the Appeals Board of the City of Albany has recommended that School District No. 5, Linn County, Oregon, be allowed to construct an addition to Sunrise School for the purpose of storing equipment, said addition being 20 feet by 30 feet in area, and

WHEREAS, said Appeals Board has recommended certain restrictions be imposed as a condition for allowing the construction of said addition, said addition being in excess of the allowable area as set forth in the Uniform Building Code, and

WHEREAS, the restrictions as recommended by the Appeals Board require the addition be constructed with exterior walls of not less than one (1) hour fire resistance rating, now, therefore,

BE IT RESOLVED that School District No. 5, Linn County, Oregon, be authorized to construct an addition to Sunrise School for the purpose of storage, said addition to be 20 feet by 30 feet on the condition that all exterior walls shall be of a fire resistance rating of not less than one (1) hour and the wall adjacent to the existing building shall also be of one (1) hour fire resistance rating.

DATED this 13th day of July, 1960.



Mayor