



RESOLUTION NO 6777

A RESOLUTION AMENDING THE CITY OF ALBANY'S LOCAL LIMITS FOR THE DISCHARGE OF POLLUTANTS OF CONCERN TO THE PUBLICLY OWNED TREATMENT SYSTEM AND REPEALING RESOLUTION NO 3624

WHEREAS, Federal regulations 40 CFR Part 403.5 require Publicly Owned Treatment Works (POTWs) to develop local limits for the discharge of pollutants of concern to the wastewater treatment system, and

WHEREAS, the State Department of Environmental Quality (DEQ) is designated as the Approval Authority to regulate POTWs in Oregon and has required the City of Albany to develop and revise local limits for the discharge of pollutants of concern to the wastewater treatment system, and

WHEREAS, the Albany Municipal Code Chapter 10.01.040 requires the development and revision of standards for specific restricted substances, and

WHEREAS, the City of Albany and its consultants have developed revised local limits (Exhibit A) using methods provided by DEQ, DEQ has provided a letter conditionally approving the revised local limits technical evaluation, and the Environmental Protection Agency's Region 10 office has been provided with proper notification by DEQ

NOW, THEREFORE, BE IT RESOLVED by the Albany City Council that the revised local limits specifically described in Exhibit "A" (attached hereto) are hereby adopted and in force upon program modification approval by DEQ, and

BE IT FURTHER RESOLVED that Resolution No 3624 is hereby repealed

DATED AND EFFECTIVE THIS 27TH DAY OF FEBRUARY 2019



Mayor

ATTEST




City Clerk

Exhibit A- City of Albany 2019 Revised Local Limits

Constituent	Unit	Local Limit
Arsenic	mg/L	1 0
Cadmium	mg/L	0 44
Chromium	mg/L	2 8
Copper	mg/L	3 4
Cyanide	mg/L	1 2
Lead	mg/L	0 7
Mercury	mg/L	0 08
Molybdenum	mg/L	0 84
Nickel	mg/L	1 6
Oil and Grease, Total	mg/L	300
pH	s u range	6 0 – 10 0
Selenium	mg/L	0 72
Silver	mg/L	1 1
Zinc	mg/L	1 5