



NOTES:

1. THE VALVE BOX ASSEMBLY SHALL CONSIST OF A MAXIMUM OF 3 COMPONENTS: THE ADJUSTABLE CAST IRON VALVE BOX FRAME AND COVER, AND A 6" DIAMETER SPOOL OF PVC 3034 PIPE IN ONE PIECE FROM THE VALVE TO 6" INSIDE THE VALVE BOX.
2. ADJUSTABLE VALVE BOXES SHALL BE SUPPLIED WITHOUT BOTTOM FLANGES.
3. THE VALVE BOX ASSEMBLY SHALL BE INSTALLED PLUMB AND CENTERED OVER THE OPERATING NUT ON THE VALVE.
4. WHERE VALVE BOXES ARE LOCATED ADJACENT TO PCC OR AC SURFACES, THOSE SURFACES SHALL BE EXTENDED TO CONSTRUCT A COLLAR AROUND THE VALVE BOX. WHERE VALVE BOXES ARE LOCATED OUTSIDE OF PCC OR AC SURFACES A PCC COLLAR SHALL BE CONSTRUCTED AROUND THE VALVE BOXES, MEASURING NO LESS THAN 18" X 18" X 4".

CITY OF ALBANY, OREGON		
PUBLIC WORKS DEPARTMENT		
STANDARD VALVE BOX DETAIL		
NO SCALE	OCTOBER 2013	NO. 502